Title 159 – Underground Storage Tanks

CHAPTER 12 INSPECTIONS

001. SAFETY INSPECTIONS

Periodic safety inspections will be conducted by State Fire Marshal personnel. All tanks will be subject to at least one inspection annually.

001.01 Inspections will include, but not be limited to, inspection of release detection records, release detection equipment, vent pipes and dispenser systems, corrosion protection records, and applicable fire safety codes.

001.02 Findings of irregularities or insufficient record or monitoring procedures may result in an order by the State Fire Marshal to correct all such problems. State Fire Marshal personnel will perform a follow-up inspection to ensure compliance with the order. At that time, all tanks found not in compliance may have their operating permits suspended or revoked until such time as the order is followed.

002. SPOT CHECKS

Periodic spot checks of tank monitoring systems will be conducted by State Fire Marshal personnel.

002.01 Inspections will cover monitoring systems and inventory control procedures.